

Office of The Chief Medical Officer, Ghaziabad

Ref.No: DSO/IDSP/2023/2047

Date:- 08-06-2023

Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Sujeet rai from IDSP UNIT, Ghaziabad inspected the premises GURUKUL THE SCHOOL, NH-9, 28 KM, DELHI MILESTONE, GHAZIABAD on 26-05-2023 and found GURUKUL THE SCHOOL, NH-9, 28 KM, DELHI MILESTONE, GHAZIABAD has safe water facilities for the person is maintaining hygienic sanitation conditions in the swimming pool or organization. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

Based on Ref: DSO/IDSP/2023/2047


(Dr. R K Gupta)

District Public Health Expert
Ghaziabad
District Surveillance Officer
District Public Health Expert
District Ghaziabad

To

GURUKUL THE SCHOOL,
NH-9, 28 KM, DELHI MILESTONE,
GHAZIABAD.



Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2023/2047

Dated 08/06/2023

WATER TEST REPORT

ADDRESS:- GURUKUL THE SCHOOL, NH-9, 28 KM, DELHI MILESTONE, GHAZIABAD.

No of sample collected : 01

Date of sample collected : 26-05-2023

Sample collection area

Sample collection area	Sample ID	Result
SWIMMING POOL	683	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation

CHLORINE STATUS : Satisfactory


Comments:-


H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water safe for Swimming.


Lab Technician
IDSP Lab
Ghaziabad


(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad


(Dr R.K Gupta)
District Surveillance Officer
Ghaziabad
District Surveillance Officer
District Public Health Expert
District Ghaziabad